




Since-1999

GSTIN- 23AGQPD0362E1ZV

THE NEW KNOT SALES AND MARKETING

209, LIG-II, Indira Nagar, Agar Road, Ujjain (M.P.) 456001
Ph. 0734- 2580386 Mob. 9826088832 ,E mail : ujnksm@rediffmail.com



An  Registered & ISO 9001:2015 Certified Firm

CERTIFICATE

NKSM/2024/1080

Client Name	Ilva Hr Sec School, Indore
Address	31, Sapna Sangeeta Road, Behind Lotus, Sneha Nager, Navlakha, Indore,
Contact No.	9826020082
Certificate Validity	20 March 2024 To 19 Mar 2027

This is to certify that following types of fire extinguishers, which are installed at the premises of our Client, are sufficient for fire safety.

All these fire extinguishers have been hydro tested, inspected, refilled and our technician has carried out servicing.

No.	Type of fire extinguishers	Capacity	IS: Specification	MFG Year.	Hpt. date		Quantity
					Done	Due	
01.	ABC Stored Pressure	04 Kgs.	15683:2006	2017	2024	2027	01 No.
02.	ABC Stored Pressure	04 Kgs.	15683:2006	2017	2024	2027	01 No.
03.	ABC Stored Pressure	04 Kgs.	15683:2006	2017	2024	2027	01 No.
04.	ABC Stored Pressure	04 Kgs.	15683:2006	2017	2024	2027	01 No.
05.	ABC Stored Pressure	04 Kgs.	15683:2006	2017	2024	2027	01 No.
06.	ABC Stored Pressure	04 Kgs.	15683:2006	2017	2024	2027	01 No.
07.	Dry Chemical Powder	05 Kgs.	IS: 2171	2017	2024	2027	01 No.
08.	Carbon Dioxide	02 Kgs.	15683:2006	2017	2024	2027	01 No.
09.	Carbon Dioxide	04.5 Kgs.	15683:2006	2017	2024	2027	01 No.
Total							09 Units

Practical demonstration on the fire extinguishing by abc type fire extinguishers on fire was performed to make staff understand capabilities of the extinguishers.

Hence we certify that all fire extinguishers are perfect and adequate for operation.


()

Vishwas Dubey
For- The New Knot Sales And Marketing,
Ujjain (M.P.)

AIM

ZER  INCIDENT → In 2024

PRINCIPAL

ILVA H. S. SCHOOL
INDORE - 452 001 (M.P.)